

certificate



The applicant:

ROSCO IBÉRICA, S.A.
c/ del Oro, 76 Pol. Ind. Sur
28770 COLMENAR VIEJO - MADRID

is authorized to place the label " Certificate of curtains fire behaviour "
according to the report Nº 2010AN1485



aitex

instituto tecnológico textil

**CERTIFICATE OF FIRE
BEHAVIOUR OF:**

CURTAINS

Nº 10AN1485

The sample reference:

"TEJIDO ROSCOTEX COMMANDO CLOTH"



has been tested according to the standards UNE-EN 1101:1996 (equivalent to EN 1101:1995) and UNE-EN 13772:2003 (equivalent to EN 13772:2003). The classification according to standard UNE-EN 13773:2003 (equivalent to EN 13773:2003) is:

"CLASS 1"

This certificate has validity until the March 21st 2015
Alcoy, March 22nd 2010.



Raquel Muñoz González
CHIEF OF LABORATORIES AREA



Jordi Ferré Pascual
HEAD OF FIRE DEPARTMENT